



- GENERAL NOTES REGARDING FIRE EXTINGUISHERS (F/E):**
1. FIRE EXTINGUISHERS PROVIDED AS SHOWN IN CONFORMANCE WITH CANULC-5503
 2. 2 CLASS A F/E WITH 2A RATING PROVIDED WITH EACH PUBLIC
 3. CORRIDOR MOUNTED NOT MORE THAN 1.5m ABOVE FINISHED FLOOR.
 4. MAXIMUM TRAVEL DISTANCE TO A F/E IS 25m.
 5. COVERAGE FOR EACH AT 800sm.
 6. MECHANICAL / ELECTRICAL ROOM, & ELEVATOR MACHINE ROOM PROVIDED WITH 1 CLASS C F/E (5C RATING)
- F/E - DENOTES - FIRE EXTINGUISHER

11	ISSUED FOR CONSTRUCTION	JAN. 3/15	GN
10	ISSUED FOR TENDER AND BUILDING PERMIT-TOWN OF BROCK	JULY 13/15	GN
9	ISSUED FOR ROOF TRUSS LAYOUT	JUNE 24/15	GN
8	ISSUED FOR COORDINATION	JUNE 10/15	GN
7	ISSUED FOR COORDINATION	JUNE 5/15	GN
6	REVISIONS TO SUITE LAYOUTS	MAY 9/15	GN
5	ISSUED FOR COORDINATION	APR. 2/15	GN
4	ISSUED FOR COORDINATION	JAN. 24/15	GN
3	ISSUED FOR SITE PLAN APPLICATION	FEB. 21/15	GN
2	ISSUED FOR CLIENT REVIEW	FEB. 15/15	GN
1	ISSUED FOR CLIENT REVIEW	SEP. 14/11	GN
NO.	REVISIONS	DATE	BY:
"ALL DRAWINGS, SPECIFICATIONS AND RELATED DOCUMENTS ARE THE COPYRIGHT PROPERTY OF THE ARCHITECT AND MUST BE RETURNED UPON REQUEST. REPRODUCTION OF DRAWINGS, SPECIFICATIONS AND RELATED DOCUMENTS IN PART OR WHOLE IS FORBIDDEN WITHOUT THE ARCHITECT'S WRITTEN PERMISSION." DRAWINGS SHALL NOT BE SCALED			
CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS ON THE JOB			
NATALE ARCHITECT INC. Suite 215 2444 Dundas St. West Mississauga, Ontario M5S 2E5 Tel: (416) 233-0207 Fax: (416) 233-0207			
ONTARIO ASSOCIATION OF ARCHITECTS GRAND NATALE LICENCE 4184 JAN. 3/14			
PROJECT: NEW 2 STOREY BUILDING: SENIORS RESIDENCE 100 MCKAY STREET GANNINGTON, ONTARIO			
DRAWING: SECOND FLOOR PLAN			
THIS DRAWING SHALL NOT BE USED FOR CONSTRUCTION UNLESS COUNTERSIGNED BY:			
DRAWN BY: nm		CHECKED BY: GN	
DATE AUG. 2011		SCALE AS NOTED	
PROJECT No.		DRAWING No.	
16-16		A4	